



# WESTBURY FIRE DEPARTMENT

## Hose Company #2



### Portable Master Stream Devices

NFPA 1001 (2013) - 5.3.8

NYS FF SKILL 17-I-7

Name/Badge: \_\_\_\_\_ Co: \_\_\_\_\_ Evaluation Type: \_\_\_\_\_

Instructor/Badge: \_\_\_\_\_ Instructors Signature: \_\_\_\_\_ Date: \_\_\_\_\_

<i>Time Limit for Station 15 Minutes</i>	NO	YES
Has FF Removed the Device from Apparatus and carried to designated location		
<i>Has FF selected a location with a solid and level surface</i>		
Has the FF selected the largest water source possible for the device/nozzle		
Has the FF connected the water source to nozzle and secured it before charging		
Has FF adjusted nozzle so not pointing downward before charging		
Does FF have control over nozzle before requesting water		
Has FF directed flow and steadies device as needed for the operation		
<b>Has Firefighter Displayed Competency on the use of a Portable Master Stream</b>		

Instructor Notes