

**Hose Co 2 – March 2018 Drill**  
**Handline Operations**

Locations – SUNY OW – Vacant Dorms

**All 3 Person Hands On evolutions**

( Operator can be Instructor – No water being flowed, just for communications)

Objective 1. -

**Pulling Mattydale or Crosslay:**

- Nozzle Pulling folds and keeping folds in tack – to front door, then staging for entry
- Back up Pulling folds and keeping folds in tack – to front door, then staging for entry behind Nozzles hose
- Control – clearing bed – getting hose taut from engine to back up position before orders to charge.

Objective 2. -

**Pulling combo Line:**

- Keeping nozzle Horseshoe in tack – to fire floor stairway door, Where dropped and staged up the stairs for easy advancement using gravity to their advantage
  - Want to see doors chocked open – so not pinching hose as charges
- Keep Back up Horseshoe in tack – to the ½ landing below where the nozzle horseshoe was dropped, it's to be staged up the stairs and out of the way of the doorway will be entering.
- Coordination between Control position and Chauffeur – lines counted, “accurate count” of lines pulled from bed
  - Once total length figured “ Nozzle or Officer “stating were in place”

- Control follows, hose all the way to back up, staging hose for easy advancement.

Objective 3.

**Creating a combo Line from dead bed:**

Same objectives as above with the 4 positions: This time going floor above 1<sup>st</sup>.

This time Nozzle - taking 50' Dead bed 1 ¾ hose ( to Same as a

Back Up - taking 50' Dead bed 1 ¾ hose

Control - getting 100' 1 ¾ off bed, attaching to 2 ½ dead bed continuing

Rest of way

- Want to see Control ask Chauffer how much is on 1<sup>st</sup> length the add 50' more then.

Objective 4.

**Setting and Staging Standpipe Hose in Stairways:**

Using 3 Lengths standpipe hose ( No Stand Pipe outlet – control will verbalized what they would do ) - Floor below door of entry:

Connect 3 lengths and stage hose for entry into fire floor

Objective 5.

**Packing a Mattydale/Cross Lay :**

- 50' in – 1 layer of hose then – long loops
- 100' the 2<sup>nd</sup> long loops ( neither to obstruct pump panel)
- Packed so 1 nozzle out either side of engine

Objective 6.

**Packing the combo Line :**

- Setting a nozzle horseshoe
- Setting a back up Horseshoe
- Setting hose in bed ( Packing dead bed hose )

Objective 7.

**Packing Standpipe hose :**

- Creating 50' lengths
- Creating 100 Packs

Objectives 1 – 3 are the basis of all fires we'll go to, do these proficiently = the sooner we get water on the fire = the sooner things will get better = the more lives and property can be saved.

As Basic as some make perceive this drill, we continue to struggle. Depending on who is there, build that muscle memory , that the thinking away from the equation!

## Westbury FD - Hose Company 2

### Handline Operations - Members Assessment Form

<b>Pulling Preconnected Hose</b>	Yes	No
Has firefighter demonstrated pulling hose from a preconnect bed		
Has Firefighter carried folds intact to the place of deployment		
Has firefighter staged hose for easy advancement- clearing kinks		
Has firefighter assured adequate flow of water prior to entry		

<b>Pulling Deadbed Hose</b>	Yes	No
Has firefighter demonstrated pulling hose from a Deadbed		
Has Firefighter pulled the correct/ asked for quantity of hose		
Has Firefighter carried folds intact to the place of deployment		
Has firefighter staged hose for easy advancement - clearing kinks		

<b>Creating a Combination Line - 1.75" Reduced from 2.5" hose</b>	Yes	No
Has firefighter demonstrated pulling hose from a Deadbed		
Has Firefighter pulled the correct/ asked for quantity of hose		
Has the Firefighrer reduced the 2.5" hose to 1.75" using a reducer		
Has Firefighter carried folds intact to the place of deployment		
Has firefighter staged hose for easy advancement - clearing kinks		

<b>Pulling and staging Standpipe Hose</b>	Yes	No
Has firefighter demonstrated pulling correct standpipe hose		
Has firefighter demonstrated connecting standpipe hose together		
Has firefighter staged hose for easy advancement - clearing kinks		
Has firefighter chocked door open when advancing hose from stairway		

<b>Packing Preconnect Bed</b>	Yes	No
Has firefighter demonstrated packing preconnect hose		
Has firefighter demonstrated setting long folds 50', and 150'		

<b>Packing Combination Line</b>	Yes	No
Has firefighter demonstrated packing deadbed hose		
Has firefighter reduced 2.5" hose to 1.75" packing 200' of 1.75" on top of 2.5" hose		
Has firefighter demonstrated making a Horseshoe pack with 50' Hose		
Has firefighter Set 1 Nozzle and 1 Back up horseshoe pack - Nozzle On top Back up		

<b>Packing Standpipe Hose</b>	Yes	No
Has firefighter demonstrated packing 50' standpipe hose pack		
Has firefighter demonstrated marrying (2) 50' packs into (1) 100' pack		

<b>Displayed Compentancy in Hose line Operations</b>	Yes	No
Has Firefighter demonstrated compantancy - ( <b>No more then 1 No per Unit</b> )		

Firefighter Name: \_\_\_\_\_

Date: \_\_\_\_\_

Instructor Name: \_\_\_\_\_