



# WESTBURY FIRE DEPARTMENT

## Hose Compay #2



### One Person SCBA Bottle Change

NFPA 1001 (2013) - 5.3.1      NYS FF SKILL 6-I-10

Name/Badge: \_\_\_\_\_ Co: \_\_\_\_\_ Evaluation Type: \_\_\_\_\_  
 Instructor/Badge: \_\_\_\_\_ Instructors Signature: \_\_\_\_\_ Date: \_\_\_\_\_

NO      YES

Has the FF place SCBA on firm clean surface		
Has the FF fully closed cylinder valve		
Has the FF bleed air from high and low pressure hoses		
Has the FF disconnected the high pressure hose from the cylinder		
Has the FF removed the empty cylinder from the harness assembly		
Has the FF verified the replacement cylinder is 90-100 % the rated capacity		
Has the FF checked cylinder valve for damage and inspected O ring in hose fitting		
Has the FF placed new cylinder into the harness/backpack assembly		
Has the FF connected the high pressure hose to the cylinder and hand tightened		
Has the FF slowly opened cylinder valve and listened for audible alarms ( PASS and Vibe-alert ) as well as any audible air leaks		
Has the FF donned regulator and taken a normal breath		
Has the FF checked pressure readings at remote gauge and heads up and verifying there is consistency within department standards		
Has the FF verbalized removing SCBA from service, Writing Work order and notifying company officer when any faults are found with the SCBA		
<b>Has Firefighter Displayed Competency one person SCBA Bottle Change</b>		

Instructor Notes