

WESTBURY FIRE DEPARTMENT

Hose Compay #2				
Doffing PPE & SCBA				
NFPA 1001 (2013) - 5.1.2, 5.3.2, 5.3.3	NYS	FF SKILL 6-I-5		
	Co:	Evaluation Ty		

Name/Badge:	Badge: Co: Evaluation Type:			
Instructor/Badge:	Instructors Signature:	Date:		
		NO	YES	
	Has the FF removed facepiece from SCBA			
	Has the FF closed cylinder valve completely			
Has the FF bleed a	air from high and low presure hoses, listened for low air alarm			
Has the FF checke	ed air cylinder pressure and replaced cylinder if less than 90% full			
Has the FF ret	turned all straps, valves and components to state of ready			
Has the FF inspe	ected SCBA and facepiece for damage and need for cleaning			
Has the FF cleane	ed equipment as needed and removed damaged equipment,	ļ		
verbalize	ed writing a work order and notifing company officer			
Has the Fi	F placed SCBA back in service ready for immediate use			
	Has the FF removed protective clothing			
Has the	FF inspected PPE for damage and need for cleaning			
Has the FF clea	ned PPE as needed and removed damage items for service,			
verbalize	ed writing a work order and notifing company officer			
H	las the FF placed PPE clothing in a ready state			
Has Fire	fighter Displayed Compentacy on Doffing SCBA and PPE			
	Instructor Notes			