



WESTBURY FIRE DEPARTMENT

Hose Compay #2



Donning Personal Protective Equipment

NFPA 1001 (2013) - 5.1.2, 5.3.1, 5.3.2, 5.3.3

NYS FF SKILL 6-I-1

Name/Badge: _____ Co: _____ Evaluation Type: _____

Instructor/Badge: _____ Instructors Signature: _____ Date: _____

For **Both** Interior and Exterior Firefighters

Time Limit 1 Minute - Time starts when first touches any article of gear

NO YES

Has the FF donned Boots and Pants (includes all fasteners and suspenders)		
Has the FF donned protective hood		
Has the FF donned coat with closure secured and collar up		
Has the FF donned helmet with eye protection and has chin strap fastened		
Has the FF donned structural firefighting gloves (no skin at wrist exposed)		
Has Firefighter Displayed Competency on Donning PPE		

Donning Self-Contained Breathing Apparatus

NFPA 1001 (2013) - 5.3.1, 5.3.2, 5.3.3

NYS FF SKILL 6-I-2, 6-I-3, 6-I-4

Only for Interior Structural Firefighters

Time Limit 1 Minute - Time starts when first touches any part of SCBA

NO YES

Has the FF positioned SCBA with Valve end away and Cylinder down, with all harness straps extended		
Has the FF opened cylinder valve completely, listened for integrated PASS alarm and listened for the low air alarm		
Has the FF checked cylinder gauge and regulator gauge and ensured consistent with manufacturers and department recommended limits		
Has the FF donned SCBA using an approved donning method (all strap cinched)		
Has the FF donned SCBA facepiece over the head and securely tighten the straps pulling straight back, not to the side, and testing for proper seal		
Has the FF donned hood (no skin exposed) and helmet (chin strap cinched)		
Has the FF Donned gloves (no skin at wrist exposed)		
Has the FF connected air supply to facepiece		
Has Firefighter Displayed Competency on Donning SCBA		